



# Certificate of Compliance

Certificate Number: LR 18037-274

Revision: LR 18037-283

Date Issued: April 22, 1997

Issued To: **THE FOXBORO CO.**  
33 Commercial St.  
M.S. N05-4a  
Foxboro, MA 02035  
USA  
Attention: Mr. Albert K. Stafford

*The products listed below are eligible to bear the CSA Mark.*

Issued By: R. Wildish  
Toronto, Ontario

Signature

## CLASS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

## PRODUCTS

Class I, Div 2, Groups A, B, C and D; Class II, Div 2, Groups F and G; Class III; Type 4X.

- Magnetic Flow Tube, Models 80xA-xxxxJxCNZ-x, 93xA-SIxPxJxL and 93xA-SIxxxJxN-x; powered by Foxboro Series IMT Transmitters; Max Ambient 70 Deg C; MWP 720 psi.

Certificate No: LR 18037-274



Date: April 22, 1997

Revision: LR 18037-283

**APPLICABLE REQUIREMENTS**

CSA Std C22.2 No.	25-1966	- Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
CAN/CSA-C22.2 No.	94-M91	- Special Purpose Enclosures
CSA Std C22.2 No	142-M1987	- Process Control Equipment
CSA Std C22.2 No.	213-M1987	- Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

**MARKINGS**

- Company Name
- Model number
- Serial number
- Electrical rating
- CSA Monogram
- Hazardous Location designation
- Special purpose enclosure designation, "Type 4X"
- Max ambient
- Caution re Disconnection of Equipment....



## *Supplement to Certificate of Compliance*

Certificate Number: LR 18037-274

Issued To: **THE FOXBORO CO.**  
33 Commercial St.  
M.S. N05-4a  
Foxboro, MA 02035  
USA  
Attention: Mr. Albert K. Stafford

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

Issued By: R. Wildish  
Toronto, ON Canada

Signature



---

### **Product Certification History**

---

Revision	Date	Description
-283	April 22/97	Addition of new model codes.